

The challenges of mainstream deammonification process for municipal used water treatment

Guangjing Xu · Yan Zhou · Qin Yang · Zarraz May-Ping Lee · Jun Gu · Winson Lay · Yeshe Cao · Yu Liu

Received: 31 October 2014 / Revised: 17 January 2015 / Accepted: 19 January 2015 / Published online: 1 February 2015
© Springer-Verlag Berlin Heidelberg 2015

Abstract The deammonification process combining partial nitrification and anaerobic ammonium oxidation has been considered as a viable option for energy-efficient used water treatment. So far, many full-scale sidestream deammonification plants handling high-ammonia used water have been in successful operation since Anammox bacteria were first discovered in the 1990s. However, large-scale application of this process for treating municipal used water with low ammonia concentration has rarely been reported. Compared to the sidestream deammonification process, the mainstream deammonification process for municipal used water treatment faces three main challenges, i.e., (i) high COD/N ratio leading to denitrifiers outcompeting Anammox bacteria, (ii) numerous difficulties in selective retention of ammonia-oxidizing bacteria (AOB) over nitrite-oxidizing bacteria (NOB), and (iii) sufficient accumulation of Anammox bacteria. Therefore, this paper attempts to provide a detailed analysis of these challenges and possible solutions towards sustainable mainstream deammonification process.

Keywords Anaerobic ammonium oxidation · Deammonification · Ammonia-oxidizing bacteria · Nitrite-oxidizing bacteria · Soluble COD

G. Xu · Y. Zhou · Q. Yang · Z. M.-P. Lee · J. Gu · Y. Liu
Advanced Environmental Biotechnology Centre, Nanyang Environment and Water Research Institute, Nanyang Technological University, 1 Cleantech Loop, Singapore 637141, Singapore

Y. Zhou · Q. Yang · J. Gu · Y. Liu (✉)
School of Civil and Environmental Engineering, Nanyang Technological University, 50 Nanyang Avenue, Singapore 639798,
Singapore
e-mail: cyliu@ntu.edu.sg


W. Lay · Y. Cao
Public Utilities Board, Singapore, Singapore

Introduction

The biological nitrogen removal (BNR) process has evolved from the conventional nitrification-denitrification into anaerobic ammonium oxidation (Anammox) coupled with shortcut nitrification known as deammonification. In general, the deammonification process can be classified as sidestream for high-ammonia used water (e.g., anaerobic digester liquor) and mainstream for low-ammonia used water (e.g., municipal used water). Large-scale application of the sidestream deammonification process has been widely reported (Lackner et al. 2014), while the mainstream deammonification is being explored at its infancy stage (Regmi et al. 2014; Wett et al. 2013).

In general, municipal used water has high COD and low ammonia concentrations at the ratio of 10 to 14 for the raw used water and 7 to 10 for the settled used water (Henze et al. 2008). Evidences suggest that denitrifiers can compete with Anammox bacteria if the soluble COD (sCOD) to nitrogen ratio is larger than 0.5 in the anaerobic stage (Jenni et al. 2014). This means that the COD/N ratio must be reduced significantly for the deammonification process. For such purpose, a process configuration with two stages (e.g., A–B type process) has been adopted for mainstream deammonification of municipal used water. Organic matter should be ideally captured as much as possible at the stage A through various mechanisms (e.g., biosorption, storage, etc.), and the stage A effluent with relatively low COD/N ratio is further treated at stage B by mainstream deammonification (Fig. 1). So far, chemically enhanced primary treatment (CEPT) and high rate activated sludge (HRAS) for carbon capture have been explored as the stage A in the mainstream deammonification process for the municipal used water treatment. Moreover, captured organic carbon is directly channeled to anaerobic digester (AD) for high-efficiency production of methane biogas (Kartal et al. 2010).

Fig. 1 Process configurations of the two-stage mainstream deammonification. *PST* primary sedimentation tank, *FST* final sedimentation tank



Selective retention of the main functional species is the major challenge in the stage B of mainstream deammonification process. A key step here is to selectively retain ammonia-oxidizing bacteria (AOB) against nitrite-oxidizing bacteria (NOB) to sustain nitrification which is a prerequisite for Anammox. Anammox bacteria have been known as very slow-growing microbes; thus, the retention of Anammox bacteria is another challenge faced in the mainstream deammonification process. Meanwhile, heterotrophic denitrifiers can easily out-compete Anammox bacteria for nitrite in the presence of organic matters (Chamchoi et al. 2008; Jenni et al. 2014; Xu et al. 2012). Several approaches have been explored to promote retention of the slow-growing Anammox bacteria. For example, Anammox bacteria could be selectively enriched in aggregated biomass (e.g., biofilm and granules) or they could be maintained through selectively recycling Anammox biomass from the sidestream deammonification unit by cyclone or screens (Wett et al. 2013).

This review aims to discuss the technical challenges, including (i) high COD/N ratio leading to denitrifiers outcompeting Anammox bacteria, (ii) stable nitrification which needs selective retention of AOB over NOB, and (iii) sufficient accumulation of Anammox bacteria. Possible solutions towards sustainable and stable mainstream deammonification for municipal used water treatment will also be presented.

High COD/N ratio: a hurdle of the mainstream deammonification

Municipal used water typically has high COD/N ratio. This poses a big challenge for mainstream deammonification as high COD promotes growth of denitrifying bacteria which compete with Anammox bacteria for nitrite. In fact, according to the Gibbs free energy of denitrification and Anammox reactions, denitrification is thermodynamically more favorable than Anammox in the presence of soluble biodegradable COD (Kumar and Lin 2010). Furthermore, denitrifiers have growth rates and yields higher than Anammox bacteria. Hence, Anammox bacteria cannot compete with denitrifiers in the situation where soluble COD is sufficiently available.

As can be observed in Table 1, there is an inverse relationship between the nitrogen removal through Anammox and substrate COD/N ratios. In order to sustain growth of Anammox bacteria against denitrifiers, the ratio of biodegradable COD/N should be controlled at the level as low as possible, e.g., it has been suggested that the soluble COD/N ratio should be below 0.5 for deammonification to occur (Daigger 2014).

The concept of A–B stage process, as illustrated in Fig. 1, has been developed to achieve significant COD reduction at stage A. The ideal stage A unit must be able to maximize the removal of total COD, sCOD in particular, without significant impact on ammonia concentration. Organic matters present in typical municipal used water can be classified into settleable particles (>100 μm), supra-colloidal particles (1–100 μm), colloidal (1 nm–1 μm), and soluble pollutants (<1 nm) (Levine et al., 1991). According to these physical properties of dissolved and particulate organic matters in municipal used water, various options, including physical, chemical, biological, or their combinations, have been developed for high-efficiency removal and concentration of organic carbon at stage A.

Primary settling is a physical separation process by gravity, where most fine settleable solids can be removed. Generally, 50–70 % of suspended solids and 30–40 % of total COD can be removed through primary settling of raw sewage (van Haandel and van der Lubbe 2012). This implies that the COD/N ratio would be reduced to 7–10 after such a physical pretreatment, which is still too high for a sustainable Anammox growth (Table 1). To further reduce the COD/N ratio of municipal used water, CEPT has been practiced in which chemical coagulants, typically iron or aluminum salts and/or organic polyelectrolytes, are used for completely removing particulate COD. However, chemical coagulants are ineffective for removal of sCOD. In fact, it was demonstrated that particles larger than 1.2 μm could be removed efficiently by CEPT, but not particles smaller than 0.2 μm (Xu et al. 2006). In general, CEPT process can lower the total COD/N ratio to 3–6, which is still too high for Anammox bacteria to compete with denitrifiers during anaerobic step.

HRAS process has been suggested as a key unit of the stage A to reach an even lower soluble COD/N ratio. In the HRAS system, sCOD can be removed by high-efficiency intracellular

Table 1 Effect of COD and COD/N on the Anammox bacteria

COD type	COD/N	Process	Effect on Anammox bacteria	References
Propionate	0.75–1.25	One-step granule	COD/N >1.25, inhibit Anammox	(Chamchoi et al. 2008)
Fat milk	0.9–2	UASB granule	COD >300 mg/L, inhibit Anammox	(Chamchoi et al. 2008)
Starch or peptone	1–4	One-step granule	COD/N=4, Anammox sharply dropped.	(Du et al. 2014)
Glucose sucrose	0.1–1	UASB granule	COD/N=1 (COD=800) or COD/NO ₂ ⁻ >1.46 (COD=700), Anammox disappeared	(Tang et al. 2013)
Landfill leachate	0.87	One-step granule	TN removal by Anammox 68 %, by denitrification 8 %	(Wang et al. 2010)
Acetate or glucose	0.27–1.4	One-step granule	Anammox decreased with COD/N increasing to 1.4	(Jenni et al. 2014)
Acetate	0.5, 0.75	One-step biofilm	COD/N 0.5 to 0.75, TN removal rate decreased from 79 to 52 %	(Chen et al. 2009)

storage or biosynthesis and further separated together with the settled COD by biological flocculation. Normally, 55–65 % of the total COD, including 50–60 % sCOD, can be removed by a HRAS process operated at a short HRT of 0.5 h and sludge residence time (SRT) of 0.5 day respectively (Wett et al. 2007). The effluent of stage A with low soluble COD/N ratio is treated in stage B for deammonification, while part of stage A sludge with captured COD is then directed to anaerobic digester for biogas production (Fig. 1).

Obviously, the HRAS as stage A has advantages of enhancing energy recovery and reducing aeration demand. However, the challenge associated with HRAS process is the unbalanced sludge flow between sludge directed to AD for enhanced biogas production and sludge returned to stage A for COD capture. This means that when more sludge is transferred for biogas production, less sludge will be available for COD degradation and COD capture. In addition, the sludge from stage A generally has a very poor settleability due to the shorter HRT and SRT applied (James Bisogni Jr and Lawrence 1971; Chan et al. 2011). As most of COD has been captured at stage A, excess sludge produced at stage B through deammonification would be largely reduced due to slow growth rates of AOB and Anammox bacteria and low ammonia loading. This implies that part of excess sludge generated at stage B can be recycled to stage A for carbon capture. Therefore, it appears to be difficult to maintain a stable sludge concentration at stage A if the sludge is withdrawn for AD.

Instead of carbon capture, various anaerobic units, e.g., upflow anaerobic sludge blanket (UASB) and expanded granular sludge bed (EGSB), have also been employed as core methods to remove biodegradable organic matters in used waste with simultaneous biogas generation, hence considering as an alternative of stage A in the A–B stage-based deammonification process. However, dissolved methane in the anaerobic processes effluent may pose a new challenge to anaerobic pretreatment of low-strength municipal used water. The dissolved methane, if not properly controlled, may eventually be emitted causing greenhouse gas emission (Liu et al. 2013).

Selective retention of AOB against NOB: a challenge of mainstream deammonification

The shortcut nitrification is the core towards sustainable deammonification, indicating the necessity of selective retention and accumulation of AOB against NOB. This prerequisite is the biggest challenge in the mainstream deammonification process treating municipal used water due to the complementary metabolism of AOB and NOB populations.

Free ammonia (FA) and free nitrous acid (FNA) have commonly been used as control parameters of nitrification in side-stream deammonification with high ammonia (Park and Bae 2009). However, such FA-based control strategy is no longer effective in mainstream deammonification of municipal used water with low ammonia concentrations of 15 to 50 mg/L (Negulescu 2011). pH control is another option but not an economically viable approach for nitrification due to high chemical costs. In general, high temperature can be considered as an effective control strategy for nitrification in warm climate as AOB grow relatively faster than NOB at temperatures higher than 25 °C (Hellings et al. 1998). As AOB grow faster than NOB, SRT can be controlled in a range shorter than NOB retention time but longer than AOB retention time. As such, NOB can be continuously washed out of the system. Although extensive efforts have been dedicated to various attempts including intermittent aeration (Ge et al. 2014), real-time control of aeration (Claros et al. 2012), inorganic carbon (NaHCO₃) (Tokutomi et al. 2010), and bioaugmentation with AOB (Bartolí et al. 2011) to maintain sustainable mainstream nitrification, it is of yet-resolved challenge. So far, most commonly practiced engineering approaches towards nitrification are based on the alternating dissolved oxygen (DO) control and short SRT (Wett et al. 2013).

Low DO below 0.5 mg/L is beneficial to selectively repress growth of NOB due to their lower oxygen affinity compared to AOB (Laanbroek and Gerards 1993). This strategy has been adopted for the treatment of both high- and low-ammonium used water (Blackburne et al. 2008; Fernandes et al. 2013; Ruiz et al. 2003). However, recent studies showed that higher DO of around 1.5 mg/L was still beneficial to

mainstream nitritation (Cao et al. 2013; Ge et al. 2014; Regmi et al. 2014). Using a tropical full-scale used water treatment plant in Singapore as the case study, Cao et al. (2013) showed that 75 % of nitrite accumulation was achieved in the oxic units operated at the DO concentrations of 1.4–1.8 mg/L. So far, DO control has been one of the most effective ways towards nitritation as it has concomitant advantage of reducing aeration-associated operation cost.

Intermittent aeration in temporal or spatial fashion has been shown to be effective for selecting AOB against NOB. For example, 90–95 % of nitrite accumulation was achieved through intermittent aeration in a sequencing batch reactor (SBR) treating domestic used water (Guo et al. 2009; Zeng et al. 2009). This is probably due to the lag time for NOB to respond the transition from anoxic to aerobic conditions and inhibition of NOB by intermediate products (e.g., hydroxylamine) (Xu et al. 2012). Another approach is to use step-feed reactor configuration. Stable partial nitritation/denitritation had been reported in continuous plug-flow reactors with alternate anoxic and oxic (A/O) zones (Cao et al. 2013; Ge et al. 2014). However, it should be noted that such control strategy still needs further study in a sustainable mainstream deammonification process for municipal used water treatment.

Alternatively, top-up or bioaugmentation of AOB from sidestream to mainstream deammonification process can also be employed. This approach helps to faster start up, maintain, or recover the nitritation process. For instance, in Strass wastewater treatment plant, Austria, supplementation of AOB biomass from the sidestream deammonification system by a hydrocyclone helped to maintain a sustainable nitritation activity in the mainstream deammonification system (Wett et al. 2013). Indeed, it is challenging to maintain a sustainable nitritation for low ammonia used water in full-scale application, which first requires inhibition of NOB versus AOB according to their different growth conditions, such as, DO, temperature, and pH, and then followed by selective washout of NOB from the system according to SRT.

Challenges associated with effective retention of Anammox bacteria

In addition to the challenges discussed above, retention of Anammox bacteria is another challenge. Anammox bacteria grow extremely slow with a doubling time of about 11 days in a lab-scale experiment (Strous et al. 1998) and 25 days at temperature below 20 °C (Hendrickx et al. 2012). Thus, a long SRT is essential for retention of Anammox biomass in the mainstream deammonification process, especially at temperatures below 20 °C (Hendrickx et al. 2012; Lotti et al. 2014).

Granular sludge and biofilm have been suggested for effective retention of Anammox biomass (Fernández et al. 2008). So far, Anammox granules and biofilm have been reported in various kinds of bioreactors including UASB, SBR, moving bed biofilm reactor (MBBR), dynamic membrane bioreactor (DMBR), and rotating biological contactor (RBC) (Christensson et al. 2013; Joss et al. 2009; Liu et al. 2008; Meng et al. 2014; Tang et al. 2011).

In general, the ammonia concentrations are very low in the municipal used water, so the development and maintenance of Anammox granules are very challenging. Hydrocyclone has been applied for separation of Anammox aggregates from waste sludge in the sidestream deammonification, which is then returned to the mainstream deammonification process (Wett et al. 2013). Through cyclone separation and return of Anammox aggregates, the SRT of Anammox bacteria can be significantly prolonged in the system. In fact, it was shown that larger aggregates from the underflow stream of a hydrocyclone exhibited much higher Anammox activity than the smaller ones (Nielsen et al. 2005; Vlaeminck et al. 2010). Anammox aggregates are generally larger but less compressible than the AOB and NOB which grow in smaller and more compressible flocs. According to such findings, selective separation and retention by screening or sieving have been developed for Anammox aggregates (De Clippeleir et al. 2013). Other methods for the retention of Anammox bacteria may include use of carriers or membrane systems.

Remarks

By reducing aeration demand and allowing carbon to be redirected to AD for biogas generation, deammonification application in the mainstream has the potential for a used water treatment plant to be energy neutral or even become net energy producers. Organic carbon and nitrogen are decoupled and treated individually in the different systems. To date, the HRAS process shows great promise for the removal of organic matters, including both soluble COD and particle COD. However, the stability and the effluent quality of HRAS process may need to be enhanced by CEPT method to achieve the required degree of COD/N in the deammonification stage so as to avoid inhibiting Anammox bacteria. Sustainable mainstream deammonification remains a goal in the treatment of municipal used water, and current research in developing both mainstream nitritation control strategies and mainstream Anammox retention methods holds promise for attaining this goal in the near future.

Acknowledgments We would like to thank the Public Utilities Board of Singapore for financial support of this research (Contract No. 1140245). The Public Utilities Board of Singapore, however, does not necessarily agree with or endorse the contents of this manuscript.

References

- Bartrolí A, Carrera J, Pérez J (2011) Bioaugmentation as a tool for improving the start-up and stability of a pilot-scale partial nitrification biofilm airlift reactor. *Bioresour Technol* 102(6):4370–4375
- Blackburne R, Yuan Z, Keller J (2008) Partial nitrification to nitrite using low dissolved oxygen concentration as the main selection factor. *Biodegradation* 19(2):303–312
- Cao Y, Kwok BH, Yong WH, Chua SC, Wah YL, Ghani Y (2013) Mainstream partial nitrification—ANAMMOX nitrogen removal in the largest full-scale activated sludge process in Singapore: process analysis. In: *WEF/IWA Nutrient Removal and Recovery*. Presented at the WEF/IWA Nutrient Removal and Recovery, Canada
- Chamchoi N, Nitisoravut S, Schmidt JE (2008) Inactivation of ANAMMOX communities under concurrent operation of anaerobic ammonium oxidation (ANAMMOX) and denitrification. *Bioresour Technol* 99(9):3331–3336
- Chan L, Leu S-Y, Rosso D, Stenstrom MK (2011) The relationship between mixed-liquor particle size and solids retention time in the activated sludge process. *Water Environ Res* 83(12):2178–2186
- Chen H, Liu S, Yang F, Xue Y, Wang T (2009) The development of simultaneous partial nitrification, ANAMMOX and denitrification (SNAD) process in a single reactor for nitrogen removal. *Bioresour Technol* 100(4):1548–1554
- Christensson M, Ekström S, Chan AA, Le Vaillant E, Lemaire R (2013) Experience from start-ups of the first ANITA Mox plants. *Water Sci Technol* 67(12):2677–2684
- Claros J, Serralta J, Seco A, Ferrer J, Aguado D (2012) Real-time control strategy for nitrogen removal via nitrite in a SHARON reactor using pH and ORP sensors. *Process Biochem* 47(10):1510–1515
- Daigger GT (2014) Oxygen and carbon requirements for biological nitrogen removal processes accomplishing nitrification, nitrification, and Anammox. *Water Environ Res* 86(3):204–209
- De Clippeleir H, Jimenez R, Giraldo E, Wett B, Dockett N, Riffat R, Murthy AAOS (2013) Screens as a method for selective anammox retention in single stage deammonification processes. In: *WEF/IWA Nutrient Removal and Recovery*. Presented at the WEF/IWA Nutrient Removal and Recovery, Canada
- Du R, Peng Y, Cao S, Wu C, Weng D, Wang S, He J (2014) Advanced nitrogen removal with simultaneous Anammox and denitrification in sequencing batch reactor. *Bioresour Technol* 162:316–322
- Fernandes H, Jungles MK, Hoffmann H, Antonio RV, Costa RHR (2013) Full-scale sequencing batch reactor (SBR) for domestic wastewater: performance and diversity of microbial communities. *Bioresour Technol* 132:262–268
- Fernández I, Vázquez-Padín JR, Mosquera-Corral A, Campos JL, Méndez R (2008) Biofilm and granular systems to improve Anammox biomass retention. *Biochem Eng J* 42(3):308–313
- Ge S, Peng Y, Qiu S, Zhu A, Ren N (2014) Complete nitrogen removal from municipal wastewater via partial nitrification by appropriately alternating anoxic/aerobic conditions in a continuous plug-flow step feed process. *Water Res* 55:95–105
- Guo JH, Peng YZ, Wang SY, Zheng YN, Huang HJ, Ge SJ (2009) Effective and robust partial nitrification to nitrite by real-time aeration duration control in an SBR treating domestic wastewater. *Process Biochem* 44(9):979–985
- Hellinga C, Schellen A, Mulder J, Van Loosdrecht M, Heijnen J (1998) The SHARON process: an innovative method for nitrogen removal from ammonium-rich waste water. *Water Sci Technol* 37(9):135–142
- Hendrickx TLG, Wang Y, Kampman C, Zeeman G, Temmink H, Buisman CJN (2012) Autotrophic nitrogen removal from low strength waste water at low temperature. *Water Res* 46(7):2187–2193
- Henze M, van Loosdrecht M, Ekama G, Brdjanovic D (2008) *Biological wastewater treatment: principles, modelling and design*. IWA Pub, London
- James Bisogni Jr J, Lawrence AW (1971) Relationships between biological solids retention time and settling characteristics of activated sludge. *Water Res* 5(9):753–763
- Jenni S, Vlaeminck SE, Morgenroth E, Udert KM (2014) Successful application of nitrification/anammox to wastewater with elevated organic carbon to ammonia ratios. *Water Res* 49:316–326
- Joss A, Salzgeber D, Eugster J, König R, Rottermann K, Burger S, Fabijan P, Leumann S, Mohn J, Siegrist H (2009) Full-scale nitrogen removal from digester liquid with partial nitrification and anammox in one SBR. *Environ Sci Technol* 43(14):5301–5306
- Kartal B, Kuenen J, Van Loosdrecht M (2010) Sewage treatment with anammox. *Science* 328(5979):702–703
- Kumar M, Lin J-G (2010) Co-existence of anammox and denitrification for simultaneous nitrogen and carbon removal—strategies and issues. *J Hazard Mater* 178(1–3):1–9
- Laanbroek H, Gerards S (1993) Competition for limiting amounts of oxygen between *Nitrosomonas europaea* and *Nitrobacter winogradskyi* grown in mixed continuous cultures. *Arch Microbiol* 159(5):453–459
- Lackner S, Gilbert EM, Vlaeminck SE, Joss A, Hom H, van Loosdrecht MCM (2014) Full-scale partial nitrification/anammox experiences—an application survey. *Water Res* 55:292–303
- Levine AD, Tchobanoglous G, Asano T (1991) Size distributions of particulate contaminants in wastewater and their impact on treatability. *Water Res* 25(8):911–922
- Liu S, Yang F, Xue Y, Gong Z, Chen H, Wang T, Su Z (2008) Evaluation of oxygen adaptation and identification of functional bacteria composition for anammox consortium in non-woven biological rotating contactor. *Bioresour Technol* 99(17):8273–8279
- Liu Z-h, Yin H, Dang Z, Liu Y (2013) Dissolved methane: a hurdle for anaerobic treatment of municipal wastewater. *Environ Sci Technol* 48(2):889–890
- Lotti T, Kleerebezem R, van Loosdrecht MCM (2014) Effect of temperature change on anammox activity. *Biotechnol Bioeng*. doi:10.1002/bit.25333
- Meng F, Su G, Hu Y, Lu H, Huang L-N, Chen G-H (2014) Improving nitrogen removal in an ANAMMOX reactor using a permeable reactive biobarrier. *Water Res* 58:82–91
- Negulescu M (2011) *Municipal Waste Water Treatment*. Elsevier Science, pp 28
- Nielsen M, Bollmann A, Sliemers O, Jetten M, Schmid M, Strous M, Schmidt I, Larsen LH, Nielsen LP, Revsbech NP (2005) Kinetics, diffusional limitation and microscale distribution of chemistry and organisms in a CANON reactor. *FEMS Microbiol Ecol* 51(2):247–256
- Park S, Bae W (2009) Modeling kinetics of ammonium oxidation and nitrite oxidation under simultaneous inhibition by free ammonia and free nitrous acid. *Process Biochem* 44(6):631–640
- Regmi P, Miller MW, Holgate B, Bunce R, Park H, Chandran K, Wett B, Murthy S, Bott CB (2014) Control of aeration, aerobic SRT and COD input for mainstream nitrification/denitrification. *Water Res* 57:162–171
- Ruiz G, Jeison D, Chamy R (2003) Nitrification with high nitrite accumulation for the treatment of wastewater with high ammonia concentration. *Water Res* 37(6):1371–1377
- Strous M, Heijnen J, Kuenen J, Jetten M (1998) The sequencing batch reactor as a powerful tool for the study of slowly growing anaerobic ammonium-oxidizing microorganisms. *Appl Microbiol Biotechnol* 50(5):589–596
- Tang C-J, Zheng P, Chai L-Y, Min X-B (2013) Thermodynamic and kinetic investigation of anaerobic bioprocesses on ANAMMOX under high organic conditions. *Chem Eng J* 230:149–157

- Tang C-J, Zheng P, Wang C-H, Mahmood Q, Zhang J-Q, Chen X-G, Zhang L, Chen J-W (2011) Performance of high-loaded ANAMMOX UASB reactors containing granular sludge. *Water Res* 45(1):135–144
- Tokutomi T, Shibayama C, Soda S, Ike M (2010) A novel control method for nitrification: the domination of ammonia-oxidizing bacteria by high concentrations of inorganic carbon in an airlift-fluidized bed reactor. *Water Res* 44(14):4195–4203
- van Haandel AC, van der Lubbe JGM (2012) Handbook of biological wastewater treatment: design and optimisation of activated sludge systems. IWA Pub
- Vlaeminck SE, Terada A, Smets BF, De Clippeleir H, Schaubroeck T, Bolca S, Demeestere L, Mast J, Boon N, Carballa M, Verstraete W (2010) Aggregate size and architecture determine microbial activity balance for one-stage partial nitrification and Anammox. *Appl Environ Microbiol* 76(3):900–909
- Wang C-C, Lee P-H, Kumar M, Huang Y-T, Sung S, Lin J-G (2010) Simultaneous partial nitrification, anaerobic ammonium oxidation and denitrification (SNAD) in a full-scale landfill-leachate treatment plant. *J Hazard Mater* 175(1–3):622–628
- Wett B, Buchauer K, Fimml C (2007) Energy self-sufficiency as a feasible concept for wastewater treatment systems. In: IWA Leading Edge Technology Conference, Singapore: Asian Water, pp 21–24
- Wett B, Omari A, Podmirseg SM, Han M, Akintayo O, Gomez Brandon M, Murthy S, Bott C, Hell M, Takacs I, Nyhuis G, O'Shaughnessy M (2013) Going for mainstream deammonification from bench to full scale for maximized resource efficiency. *Water Sci Technol* 68(2):283–289
- Xu G, Xu X, Yang F, Liu S, Gao Y (2012) Partial nitrification adjusted by hydroxylamine in aerobic granules under high DO and ambient temperature and subsequent Anammox for low C/N wastewater treatment. *Chem Eng J* 213:338–345
- Xu G, Zhang Y, Gregory J (2006) Different pollutants removal efficiencies and pollutants distribution with particle size of wastewater treated by CEPT process. *Water Pr Technol* 1(03)
- Zeng W, Zhang Y, Li L, Peng YZ, Wang SY (2009) Control and optimization of nitrifying communities for nitrification from domestic wastewater at room temperatures. *Enzyme Microb Technol* 45(3):226–232